



Ref. Certif. No.

CN27097

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEMESYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC**CB TEST CERTIFICATE**Product
Produit

Low-voltage Fuse(Fuse-link with Knife Blade Contact)

Name and address of the applicant
Nom et adresse du demandeurZhejiang Mingrong Electrical Protection Co., Ltd.
Wei 11th Road,Economic Development Zone, Yueqing, Zhejiang
Province, P.R.ChinaName and address of the manufacturer
Nom et adresse du fabricantZhejiang Mingrong Electrical Protection Co., Ltd.
Wei 11th Road,Economic Development Zone, Yueqing, Zhejiang
Province, P.R.ChinaName and address of the factory
Nome et adresse de l'usineZhejiang Mingrong Electrical Protection Co., Ltd.
Wei 11th Road,Economic Development Zone, Yueqing, Zhejiang
Province, P.R.ChinaNote: When more than one factory, please report on page 2
Note: Lorsqu'il y a plus d'une usine, veuillez utiliser la 2^{ème} pageRatings and principal characteristics
Valeurs nominales et caractéristiques principalesUn:AC690V,AC500V;
In:2A,4A,6A,10A,16A,20A,25A,32A,35A,40A,50A,63A
(690V/500V), 80A,100A(500V);Rated breaking
capacity:80kA(690V),120kA(500V); Breaking Range and
Utilization Category:gG;
Ferraz ShawmutTrademark (if any)
Marque de fabrique (si elle existe)

NH000GG**-*;

Model / Type Ref.
Ref. De typeAdditional information (if necessary may also be reported
on page 2)
Les informations complémentaires (si nécessaire, peuvent être
indiqués sur la 2^{ème} page)**PUBLICATION****EDITION**A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à laIEC 60269-2:2006(third edition) see also IEC 60269-1:2006
(Fourth edition)As shown in the Test Report Ref. No. which forms part
of this Certificate
Comme indiqué dans le Rapport d'essais numéro de
référence qui constitue partie de ce CertificatC009-CB2010CQC-026240-1,C009-CB2010CQC-026240-
2This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification****CHINA QUALITY CERTIFICATION CENTRE**

Date: 2013-07-22

Signature:

Wang Kejiao