



Ref. Certif. No.

CN27098

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE

Product
Produit

Low-voltage Fuse(Fuse-link with Knife Blade Contact)

Name and address of the applicant
Nom et adresse du demandeur

Zhejiang Mingrong Electrical Protection Co., Ltd.
Wei 11th Road,Economic Development Zone, Yueqing, Zhejiang
Province, P.R.China

Name and address of the manufacturer
Nom et adresse du fabricant

Zhejiang Mingrong Electrical Protection Co., Ltd.
Wei 11th Road,Economic Development Zone, Yueqing, Zhejiang
Province, P.R.China

Name and address of the factory
Nome et adresse de l'usine

Zhejiang Mingrong Electrical Protection Co., Ltd.

Note: When more than one factory, please report on page 2
Note: Lorsque plus d'une usinem, veuillez utiliser la 2^{me} page

Wei 11th Road,Economic Development Zone, Yueqing, Zhejiang
Province, P.R.China

Ratings and principal characteristics
Valeurs nominales et caractéristiques principales

Un:AC500V,690V;
In:32A,35A,40A,50A,63A,80A,100A,125A,160A,200A,224A,2
(500/690V);355A,400A(500V);
I1:AC690V:80kA,AC500V:120kA;Breaking Range and
Utilization Category:gG

Trademark (if any)
Marque de fabrique (si elle existe)

Model / Type Ref.
Ref. De type

NH2GG**-*

Additional information (if necessary may also be reported
on page 2)
Les informations complémentaires (si nécessaire, peuvent être
indiqués sur la 2^{me} page)

PUBLICATION

EDITION

A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à la

IEC 60269-2:2006(third edition) see also IEC 60269-1:2006
(Fourth edition)

As shown in the Test Report Ref. No. which forms part
of this Certificate
Comme indiqué dans le Rapport d'essais numéro de
référence qui constite partie de ce Certificat

C009-CB2010CQC-026236-1,C009-CB2010CQC-026236-
2

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme National de Certification



CHINA QUALITY CERTIFICATION CENTRE

Date: 2013-07-22

Signature:

Wang Kejiao

Issued 2003-05
China Quality Certification Centre
Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

Tel: +86-10-83886666
Fax: +86-10-83886282

website
www.cqc.com.cn

CB 0016661