



Ref. Certif. No.

CN27095

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST  
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)  
CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE  
CERTIFICATS D'ESSAIS DES EQUIPEMENTS  
ELECTRIQUES (IECEE) METHODE OC

## CB TEST CERTIFICATE

Product  
Produit

Low-voltage Fuse(Fuse-link with Knife Blade Contact)

Name and address of the applicant  
Nom et adresse du demandeur

Zhejiang Mingrong Electrical Protection Co., Ltd.  
Wei 11th Road,Economic Development Zone, Yueqing, Zhejiang  
Province, P.R.China

Name and address of the manufacturer  
Nom et adresse du fabricant

Zhejiang Mingrong Electrical Protection Co., Ltd.  
Wei 11th Road,Economic Development Zone, Yueqing, Zhejiang  
Province, P.R.China

Name and address of the factory  
Nome et adresse de l'usine

Zhejiang Mingrong Electrical Protection Co., Ltd.  
Wei 11th Road,Economic Development Zone, Yueqing, Zhejiang  
Province, P.R.China

Note: When more than one factory, please report on page 2  
Note: Lorsqu'il y a plus d'une usine, veuillez utiliser la 2<sup>ème</sup> page

Ratings and principal characteristics  
Valeurs nominales et caractéristiques principales

Un:690V,500V;In:250A,315A,355A,400A,425A,450A,500A  
(690V/500V);630A(500V);I1:80kA(690V),120kA(500V)  
Breaking Range&Utilization Category:gG  
Ferraz Shawmut

Trademark (if any)  
Marque de fabrique (si elle existe)

NH3GG\*\*-\*

Model / Type Ref.  
Ref. De type

Additional information (if necessary may also be reported  
on page 2)  
Les informations complémentaires (si nécessaire, peuvent être  
indiqués sur la 2<sup>ème</sup> page)

PUBLICATION

EDITION

A sample of the product was tested and found  
to be in conformity with  
Un échantillon de ce produit a été essayé et a été  
considéré conforme à la

IEC 60269-2:2006(third edition) see also IEC 60269-1:2006  
(Fourth edition)

As shown in the Test Report Ref. No. which forms part  
of this Certificate  
Comme indiqué dans le Rapport d'essais numéro de  
référence qui constitue partie de ce Certificat

C009-CB2010CQC-026235-1,C009-CB2010CQC-026235-  
2

This CB Test Certificate is issued by the National Certification Body  
Ce Certificat d'essai OC est établi par l'Organisme National de Certification



CHINA QUALITY CERTIFICATION CENTRE

Date: 2013-07-22

Signature:

Wang Kejiao